



NOTES:

1. SERVICE DROP CLEARANCES ABOVE GRADE, ALLEYS, DRIVEWAYS, AND AREAS SUBJECT TO TRUCK USE, TO BE IN ACCORDANCE WITH NESC. MINIMUM GROUND CLEARANCE OF 10 FT TO THE BOTTOM OF THE DRIP LOOP IS REQUIRED PER NEC.
2. FOR CUSTOMER/ COMPANY RESPONSIBILITIES SEE SERVICE GUIDE 19.
3. SERVICE ATTACHMENT SHALL BE A SECONDARY INSULATOR WITH CLEVIS AND 5/8" DIA. BOLT FASTENED THROUGH THE POLE.
4. FOR SERVICE 400 AMPS & LARGER, CURRENT TRANSFORMER IS REQUIRED. CONTACT SUSSEX REC.